

Instituto Nicaragüense de Energía

Environmental Quality in Nicaragua

Eng. Nelly Harding. Environmental Control Director

Austin, Texas – July 2008

PRESENTATION OBJECTIVES

 Showing current power plant environmental quality. Case examples.

Environmental Requirements in Power Generation Project Implementation

Environmental Permit

Ranking by generation type

- Wind, biomass, and hydroelectric power plants under 10W are required to carry out an Environmental Assessment. The Permit is granted by MARENA Departmental Delegations.
- Thermal, geothermal, biomass, wind, and hydroelectric power plants over 10 MW are required to submit an Environmental Impact Assessment (EIA). The Permit is granted by MARENA headquarters

Source: Decree 76-2006



PERCENTAGE GENERATION BY FUEL TYPE

- Fossil Fuels
- Water
- Geothermal Steam
- Biomass

71.01% 9.55% 7.58% 11.86%

Source: INE Statistics, 2007

Power Plants

Interconnected System

- Tipitapa Power
- Censa Amfels
- Margarita Plant
- *Nicaragua Plant
- *Managua Plant
- *Las Brisas Plant
- Hugo Chávez Plants
- Huyndai Managua Plants
- Huyndai Tipitapa Plants
- Huyndai Masaya Plants
- *Centroamérica Hydropower Plant
- *Santa Bárbara Hydropower Plant
- *San Jacinto Geothermal Plant
- *Momotombo Geothermal Plant (ORMAT)
- GESARSA
- San Antonio Cogeneration
- Monte Rosa Cogeneration

Stranded Systems

- *Puerto Cabezas Power
- *EGOMSA
- Aprodebo Hydropower Plant
- Wabule Hydropower Plant
- ATDER Hydropower Plant
- *ENEL Thermal Miniplants

 Energy Structure prior to current environmental regulation

Fuel Used by Generation Type

Generation Type	Fuel	Units	Amount
Hydrocarbons	Bunker	Thousand gallons	131, 849.5
Hydrocarbons	Diesel oil	Thousand gallons	19, 848.96
Geothermal	Geothermal steam	Thousand tons of steam	2, 055.39
Hydroelectric	Water	Thousand M ³	578, 645.79
Cogeneration	Sugar cane bagasse and firewood	Metric tons	1,132,703.96 7
	INE statistics, 2007.		

Emissions from Fossil Fuels Used

- Carbon Monoxide
- Carbon Dioxide
- Lead
- Particulate Matter
- Sulphur Oxides
- Nitrogen Oxides
- Volatile Organic Compounds
- Heavy Metals (cadmium, chrome, cobalt, mercury)
- Dioxines & Furans
- Formaldehides
- Among Others.

AIR QUALITY STANDARD (NTON 05 012 02 MAXIMUM PERMISSIBLE AIR POLLUTANT EMISSION LIMITS

POLLUTANT	SYMBOL	MAXIMUM PERMISSIBLE LIMIT μg/m³ /(ppm)	MEASUREMENT PERIOD
Total Suspended Particles	TSP	75 /(n a.) 260/ (n.a)	Annual ¹ [IRM1][IRM2] 24 hours ²
Particulate Matter 10 micrometers or less	PM ₁₀	50/ (n.a) 150/ (n.a)	Annual ¹ 24 hours ²
Sulphur Dioxide	SO ₂	80 / (0.03) 365 / (0.14)	Annual ¹ 24 hours ²
Nitrogen Dioxide	NO ₂	100 / (0.05) 400 / (0.21)	Annual ¹ 1 hour ²
Ozone	03	160 / (0.08) 235/ (0.12)	8 hours ² 1 hour ²
Carbon Monoxide	CO	10,000 / (9.0) 40,000 / (35.0)	8 hours ² 1 hour ²
Lead	Pb	0.5/ (n.a) 1.5/ (n.a)	Annual ¹ Quarterly

Annual¹

: Annual arithmetic average

: Continuous

n.a.

: Not applicable because the µg/m³ / ppm ratio is only valid in cases where pollutant is a gas, instead of a particle.

Control Elements Decree on Effluents Effluents from Thermal Power Plants Measurement Parameters, Art. 43

- Temperature
- Ph
- Suspended Solids
- BOD
- COD
- Cu
- Total P
- Zn
- PCB
- Greases and Oils
- Hydrocarbons

50 °C 6-9 60mg/l 90mg/l 200mg/l 0.8 mg/l5mg/l 2mg/l NA 20mg/l 2mg/l

Case Example

Tipitapa Power Generation Plant Interconnected System

Generation Type

Location

Commissioning date Installed capacity Number of Units Storage Tanks Oily Water Treatment Mud & Oil Discharge Water Discharge

Effluent Monitoring Air Quality Thermal

Km. 19 Old Road toTipitapa, Departament of Managua March 1999 52.20 MW 5 4 Treatment system Authorized company La Mocuana River

Semiannually Semiannually













Case examples

Puerto Cabezas Power Stranded System Plant Originally State-Owned. 1.5 MW Capacity Location: Bilwi city urban grid, North Atlantic Autonomous Region

Generation type Generation fuel: Current installed capacity: Current number of tanks Number of units installed in engine room Condition of units Fuel pretreatment: Oily water and purge treatment: Water destination: Baseline study before current administration accession: Effluent monitoring Thermal Fuel Oil No. 6 7 MW 7 5 Poor Centrifugation Separator Company yards Nonexistent Not done









Houses neighboring the plant. Notice roof conditions







Tank and cooling area

-

Location of firefighting system valves

